

(i) To the maximum extent practicable, include sufficient procedural safeguards to ensure that, during or following an accident or other incident involving the nearby nuclear power plant reactor, the project may be safely operated and, if evacuation is necessary, the project may be left unattended without danger to the safety of any project dam or to life, health, or safety upstream or downstream from the project; and

(ii) Explain the provisions, developed after consultation with the direct purchasers of project power, for cessation, curtailment, or continuation of generation of electric power at the project during or following an accident or other incident involving the nearby nuclear power plant reactor.

(3) *Time of filing radiological response plan.* (i) For a constructed project with an otherwise acceptable emergency action plan on file, any radiological response plan required must be filed:

(A) If an operating license for the nuclear power plant has been issued on or before March 1, 1981, not later than three months from March 1, 1981; or

(B) In all other instances, not later than three months after the date an operating license for the nuclear power plant is issued.

(ii) For any project not described in § 12.22(c)(3)(i), any radiological response plan required must be filed contemporaneously with the emergency action plan or, if the project has been exempted from filing an emergency action plan, at the time the emergency action plan would otherwise have been required to be filed pursuant to § 12.23.

[Order 122, 46 FR 9036, Jan. 28, 1981, as amended at 49 FR 29370, July 20, 1984]

§ 12.23 Time for filing emergency action plan.

(a) *Unconstructed project.* (1) Except as set forth in paragraph (a)(2), the emergency action plan for an unconstructed project must be filed no later than 60 days before the initial filling of the project reservoir begins.

(2) *Temporary impoundment during construction.* (i) For any unconstructed project, if a temporary impoundment would be created during construction, such as through construction of temporary or permanent cofferdams or

large sediment control structures, and an accident to or failure of the impounding structures might endanger construction workers or otherwise endanger public health or safety, a temporary construction emergency action plan must be filed no later than 60 days before construction begins.

(ii) No later than 60 days before the initial filling of a project reservoir begins at a project for which a temporary emergency action plan has been filed the applicant or licensee must file modifications to that plan or a new plan, taking into account the differences in circumstances between the construction and post-construction periods.

(b) *Unlicensed constructed project.* (1) If the Commission has determined on or before March 1, 1981 that a license is required for an unlicensed constructed project, the emergency action plan for that project must be filed no later than:

(i) Six months after March 1, 1981; or
(ii) Any earlier date specified by the Commission or its authorized representative.

(2) Except as set forth in paragraph (b)(1) of this section, the emergency action plan for an unlicensed constructed project must be filed no later than the earliest of:

(i) Six months after the date that a license application is filed;
(ii) Six months after the date that the Commission issues an order determining that licensing is required; or
(iii) A date specified by the Commission or its authorized representative.

(c) *Licensed constructed project.* If a licensed constructed project does not have an acceptable emergency action plan on file on March 1, 1981 the emergency action plan must be filed no later than:

(1) Six months after March 1, 1981; or
(2) Any earlier date specified by the Commission or its authorized representative.

(d) For good cause shown, the Regional Engineer may grant an extension of time for filing all or any part of an emergency action plan.

§ 12.24 Review and updating of plans.

(a) The emergency action plan must be continually updated to reflect any